

CERTIFICATE

of constancy of performance

1922 - CPR - 1014

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Electrical automatic control and delay devices for gas extinguishing systems. Control and indicating equipment. Power supply equipment. Fire detection and extinguishing control panel- model SQS 101 (Environmental class A)

(For list of controlled characteristics, see Annexes I, II and III to 1922-CPR-1014 that are an inseparable part of this certificate)

placed on the market under the name or trade mark of

QUADEL doo.

Zorana Radosavljevica Cupe 30, Nis, Serbia

and produced in the manufacturing plant of

QUADEL doo.

Zorana Radosavljevica Cupe 30, Nis, Serbia

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12094-1:2003, EN 54-2:1997, EN 54-2:1997/AC:1999, EN 54-2:1997/A1:2006 and EN 54-4:1997, EN 54-4:1997/AC:1999, EN 54-4:1997/A1:2002, EN 54-4:1997/A2:2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 17.05.2018 and will remain valid until 02.11.2019 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.



Issued:
Burgas, 02 November 2018

Embossed stamp of "Dedal - A&C" Ltd.

Manager:



arch. Galina Vasileva


ANNEX I TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922 - CPR - 1014/02.11.2018 (page 1 of 1)

Performance list, acc. to EN 54-2:1997, EN 54-2:1997/AC:1999, EN 54-2:1997/A1:2006

| | | |
|---|------|-------|
| Performance under fire conditions | | |
| - General requirements | pass | 4 |
| - General requirements for indications | pass | 5 |
| - The fire alarm condition | pass | 7 |
| Response delay (response time to fire) | | |
| - Reception and processing of fire signals | pass | 7.1 |
| - Output of the fire alarm condition | pass | 7.7 |
| - Delay to outputs | pass | 7.11 |
| - Dependencies on more than one alarm signal | N/A | 7.12 |
| Operational reliability | | |
| - General requirements | pass | 4 |
| - General requirements for indications | pass | 5 |
| - The quiescent condition | pass | 6 |
| - The fire alarm condition | pass | 7 |
| - Fault warning condition | pass | 8 |
| - Disabled condition | pass | 9 |
| - Test condition | pass | 10 |
| - Standardized input/output interface | N/A | 11 |
| - Design requirements | pass | 12 |
| - Additional design requirements for software controlled control and indicating equipment | pass | 13 |
| - Marking | pass | 14 |
| Durability of operational reliability, temperature resistance | | |
| - Cold (operational) | pass | 15.4 |
| Durability of operational reliability, vibration resistance | | |
| - Impact (operational) | pass | 15.6 |
| - Vibration, sinusoidal (operational) | pass | 15.7 |
| - Vibration, sinusoidal (endurance) | pass | 15.15 |
| Durability of operational reliability, electrical stability | | |
| - Electromagnetic compatibility (EMC), immunity tests (operational) | pass | 15.8 |
| - Supply voltage variations | pass | 15.13 |
| Durability of operational reliability, humidity resistance | | |
| - Damp heat, steady state (operational) | pass | 15.5 |
| - Damp heat, steady state (endurance) | pass | 15.14 |



Issued:
Burgas, 02 November 2018



Manager:



arch. Galina Vasileva

**ANNEX II TO CERTIFICATE OF CONSTANCY OF PERFORMANCE
1922 - CPR - 1014/02.11.2018 (page 1 of 1)**

Performance list, acc. to EN 54-4:1997, EN 54-4:1997/AC:1999, EN 54-4:1997/A1:2002, EN 54-4:1997/A2:2006

| Performance of power supply | <i>Performance</i> | <i>Clause</i> |
|---|--------------------|---------------|
| - General requirements | pass | 4 |
| - Functions | pass | 5 |
| - Materials, design and manufacture | pass | 6 |
| Operational reliability | | |
| - General requirements | pass | 4 |
| - Functions | pass | 5 |
| - Materials, design and manufacture | pass | 6 |
| - Documentation | pass | 7 |
| - Marking | pass | 8 |
| Durability of operational reliability, temperature resistance | | |
| - Cold (operational) | pass | 9.5 |
| Durability of operational reliability, vibration resistance | | |
| - Impact (operational) | pass | 9.7 |
| - Vibration, sinusoidal (operational) | pass | 9.8 |
| - Vibration, sinusoidal (endurance) | pass | 9.15 |
| Durability of operational reliability, electrical stability | | |
| - Electromagnetic compatibility (EMC), immunity tests (operational) | pass | 9.9 |
| Durability of operational reliability, humidity resistance | | |
| - Damp heat, steady state (operational) | pass | 9.6 |
| - Damp heat, steady state (endurance) | pass | 9.14 |

This certificate was first issued on 17.05.2018 and will remain valid until 02.11.2019 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.



Embossed stamp of "Dedal - A&C" Ltd.

Issued:
Burgas, 02 November 2018

Manager:



arch. Galina Vasileva


ANNEX III TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922 - CPR - 1014/02.11.2018 (page 1 of 2)

Performance list, acc. to EN 12094-1:2003

| Characteristics | Performance | Clause |
|---|-------------|--------|
| Performance Parameters Under Fire Conditions | | |
| - Signal processing and indication | Pass | 4.3 |
| - Reception and processing of input triggering signals | Pass | 4.4 |
| - Transmission of extinguishing signal | Pass | 4.5 |
| - Activation of alarm devices | Pass | 4.6 |
| Response Delay (response time) | | |
| - Activated condition | Pass | 4.8 |
| Operational Reliability | | |
| - Environmental Class | Pass | 4.2 |
| - Signal processing and indication | Pass | 4.3 |
| - Reception and processing of input triggering signals | Pass | 4.4 |
| - Transmission of extinguishing signal | Pass | 4.5 |
| - Activation of alarm devices | Pass | 4.6 |
| - Indication of the supply with power | Pass | 4.7 |
| - Activated condition | Pass | 4.8 |
| - Indication of activated condition | Pass | 4.9 |
| - Released condition | Pass | 4.10 |
| - Indication of released condition | Pass | 4.11 |
| - Resetting of the activated condition and the released condition | Pass | 4.12 |
| - Fault warning condition | Pass | 4.13 |
| - Indication of the fault warning condition | Pass | 4.14 |
| - Disabled condition | Pass | 4.15 |
| - Indication of disabled condition | Pass | 4.16 |
| - Mechanical design | Pass | 5.2 |
| - Manual controls | Pass | 5.3 |
| - Indication by means of separate light emitting indicators | Pass | 5.4.2 |
| - Indications by means of alphanumeric displays | N/A | 5.4.3 |
| - Audible indicators | Pass | 5.5 |
| - Electrical design of components | Pass | 5.6 |
| - Circuit design | Pass | 5.7 |
| Operational Reliability | | |
| - Additional design requirements for software controlled ECD's | Pass | 6 |
| - Marking | Pass | 7 |
| - Documentation | Pass | 8 |
| Durability of Operational Reliability | | |
| - General test requirements | Pass | 9.1 |
| - Functional tests | Pass | 9.2 |
| - Environmental tests | Pass | 9.3 |
| - Damp heat, cyclic | Pass | 9.4 |
| - Sulphur dioxide (SO ₂) corrosion (endurance) | N/A | 9.5 |



Issued:
Burgas, 02 November 2018



Manager:



arch. Galina Vasileva

**ANNEX III TO CERTIFICATE OF CONSTANCY OF PERFORMANCE
1922 - CPR - 1014/02.11.2018 (page 2 of 2)**

Performance list, acc. to EN 12094-1:2003

The product is certified with the following options with requirements from EN12094-1:

1. Delay of the extinguishing signal for a period programmable in steps of 1 sec (clause 4.17)
2. Reception of a signal representing the extinguishing agent flow (Agent Released/ Discharged input) (clause 4.18)
3. Monitoring of the status of components (I/O lines controlled for open & short circuit) (clause 4.19)
4. Reception of signal from emergency hold device (Emergency hold input) (clause 4.20)
5. Control of flooding time in a period programmable in steps of 1 sec (clause 4.21)
6. Change over from "manual only" to "automatic/manual" mode (clause 4.22)
7. Transmission of a triggering signal to equipment within the extinguishing system (clause 4.24)
8. Transmission of a triggering signal to equipment outside the extinguishing system (clause 4.26)
9. Reception of signal from emergency abort device (Emergency abort input) (clause 4.27)
10. Activation of alarm devices with different signals (clause 4.30)



Issued:
Burgas, 02 November 2018

Embossed stamp of "Dedal - A&C" Ltd.

Manager:



arch. Galina Vasileva